

State / Regional / District / Public Health Laboratory BeedE-mail-ID : clp.h.l.beed.123@gmail.comPhone No. : 222863

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : 17.10.23 Date of Receipt : 17.10.2023 Date of Examination : 17.10.23LRN : 208

(All the Analytical Results are in mg./litre except pH, Turbidity)

onwards

Sr. No.	TEST PARAMETER	(1) मार्ग कोश इंटर नेशनल स्कूल, डोंगरी	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	clear			—	—
2.	Odour	Odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.42			1.0	5.0
4.	pH Value	6.5			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	20.0			250	1000
6.	Nitrates (as NO ₃)	07.27			45	No relaxation
7.	Total Hardness (as CaCO ₃)	36.0			200	600
8.	Alkalinity (as CaCO ₃)	28.0			200	600
9.	Total Dissolved Solids	140.0			500	2000
10.	Iron (as Fe)	0.192.0			0.3	No relaxation
11.	Fluoride (as F)	0.735			1.0	1.5
12.	Other Tests (if any)	—				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

Rachana
Manager
Bharti Bangar International School
Mategaon Road, Tq. Georal, Dist. Beed

Principal
Principal
Bharti Bangar International School
Mategaon Road, Tq. Georal Dist. Beed

[P.T.O.]

REMARKS

✓ A) Sample No. (s) 01 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) T Contains _____

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) _____ Contains _____

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No.

3396 / 20

Date :-

30 OCT 2023

Forwarded With Compliments To : Principal

Bhakti Bangar International School
Georai, Tq Georai Dist. Beed

With reference to letter No. : BBIS/30/2023

Dated :- 10-10-2023

Fees Rs. : 600/-

Receipt No. and Date : 8582151
17-10-2023

Jourag
Chief Bacteriologist,
Dist. Public Health Laboratory,
Beed.

Annexure C

Dated: 29/4/2024

It is certified that an inspection team headed by Dr. A. G. Gnydien

inspected the Bhadi Baniya International school mabeyard. cedm

Water Test Report (Attached) bearing no. 3396/23 dated 30/11/2023

Bharti Bangor Bheranahar (Name of school) has safe drinking water
 School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

This certificate is valid till 28/8/2024.

Name & Address of the Office / Department :

Principal, Bhaskar Binger
International School, New
(Name & Address of the Institution)

डा.गेवराई जि.बीड

Pachana Manager



Bharti Bangar International School
Mategaon Road, Tq. Georal, Dist. Beed